

Crescent Park (PWSID#: NJ1615014)
Morris Avenue, West Milford, NJ 07480
Year 2014 Annual Water Quality Report

What's The Quality of Your Water?

West Milford Township MUA is proud to supply you with this year's Water Quality Report required by the State of New Jersey Department of Environmental Protection (NJDEP) and the U.S. Environmental Protection Agency (EPA). The tables in this report show the results of our water quality analysis in the year 2014. Every regulated contaminant detected in the water, even in the minutest traces, is listed. The table contains the name of each highest level allowed by regulation (MCL), the ideal goals for public health (MCLG), usual sources of such contamination, definitions that explain what was tested, and a key to the units of measurement. *The data tables in this report show only the substances **detected** in your water; other substances may have been tested and not detected.*

Crescent Park received no violations in 2014 and all test results were below the levels allowed by the EPA in public drinking water. The EPA requires monitoring for over 80 drinking water contaminants. The contaminants listed in the table on the next page reflect only the contaminants detected in your water for the monitoring period January 1 to December 31, 2014. We routinely monitor for contaminants in your drinking water according to federal and state laws. The state allows us to monitor for some contaminants less than once per year because the concentrations of those contaminants do not change frequently. Some of our data, though representative, may be more than one year old.

Sources of Supply

Crescent Park draws its water from 2 groundwater wells. These wells utilize corrosion control and disinfection in the treatment process. It has 206 service connections and serves approximately 700 people per day.

GENERAL DRINKING WATER INFORMATION:

Water Sources

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Biological* - may come from human, agricultural, or wildlife sources.
- *Inorganic* - can be natural, from storm run-off, or from industrial or domestic wastewater discharges.
- *Pesticides and herbicides* - may come from agricultural, storm run-off or residential use.
- *Organic chemicals* - may come from industrial or domestic processes, storm run-off, and septic systems.
- *Radioactive materials* - can be naturally occurring or the result of mining or other human activities.

Presence of Contaminants

The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (1-800-426-4791). In order to ensure that tap water is safe to drink, the EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems.

Immuno-Compromised Persons

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

CRESCENT PARK WATER QUALITY TABLE

Contaminant	MCL Violation Y/N	Level Detected via # of Samples	Unit of Measurement	MCL (Highest Level Allowed)	MCLG (Goal)	Potential Source
Copper Test Results Year: 2012	N	0.9 (90 th Percentile) 10 Samples	ppm	1.3 (Action Limit)	1.3	Corrosion of household plumbing
Chromium Test Results Year: 2012	N	4 2 Sample	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
Chlorine Residual Test Results Year: 2014	N	Average: 0.7 Range: 0. – 2.2	ppm	MRDL 4	MRDLG 4	Water additive used to control microbes
THM Stage 2 Test Results Year: 2014	N	LRAA: 0.5 2 Samples	ppb	80	N/A	Disinfectant Byproducts

Secondary Contaminants

Contaminant	Average Level Detected	Range of Detections	Unit of Measurement	RUL	Potential Source
Aluminum (2012)	0.25	0.2 – 0.3	ppm	0.20	Naturally Occurring
Chloride (2012)	5.4	5.3 – 5.5	ppm	250	Naturally Occurring
Hardness (2012)	43.5	43 – 44	ppm	250	Naturally Occurring
Sulfate (2012)	7.3	7.3 – 7.3	ppm	250	Naturally Occurring
Total Dissolved Solids (2012)	50	41 – 58	ppm	500	Naturally Occurring

How to read this report:

Word, Acronym, Symbol or Note	Definition
Y/N	Yes/No
AL	Action Level. The concentration of a contaminant, which, if exceeded, triggers a treatment or other requirements, which a water system must follow.
CDC	Centers for Disease Control
EPA	United States Environmental Protection Agency.
LRAA	Locational Running Annual Average
MCL	Maximum Contaminant Level. The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
MCLG	Maximum Contaminant Level Goal. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MRDL	Maximum Residual Disinfectant Level – The highest level of a disinfectant allowed in drinking water.
MRDLG	Maximum Residual Disinfectant Level Goal – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
N/A	Not applicable
NJDEP	New Jersey Department of Environmental Protection
ND	Not detected
ppb	Parts per billion. Means 1 part per 1,000,000,000 (same as micrograms per liter) and correspond to 1 penny in \$10 million.
ppm	Parts per million. Means 1 part per 1,000,000 parts (same as milligrams per liter) and corresponds to 1 penny in \$10,000.
RUL	Recommended Upper Limit

Health Effects of Detected Contaminants:

Aluminum: Large aluminum intake may be connected with nerve damage. Particularly people with kidney damage are susceptible to aluminum toxicity and there is a risk of allergies. A correlation between aluminum uptake and an increased number of Alzheimer cases is suspected. Increased aluminum intake may also cause osteomalacia.

Chromium: Some people who use water containing chromium well in excess of the MCL over many years could experience allergic dermatitis.

Chloride: Chloride occurs naturally in water and is monitored as a secondary contaminant. Secondary contaminants are aesthetic (taste and odor) rather than health risks; however, in high concentrations sulfate can cause Diarrhea in some people.

Chlorine: Some people who use water containing chlorine well in excess of the MRDL could experience irritating effects to their eyes and nose. Some people who drink water containing chlorine well in excess of the MRDL could experience stomach discomfort.

Copper: Copper is an essential nutrient, but some people who drink water that contains copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water that contains copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson's Disease should consult their personal doctor.

Hardness: Water hardness is the traditional measure of the capacity of water to react with soap and producing lather. Hard water often produces a noticeable deposit of precipitate (e.g. insoluble metals, soaps or salts) in containers, including "bathtub ring".

Nitrate: Nitrate in drinking water a levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant, you should ask for advice from your health care provider.

Sulfate: Sulfate occurs naturally in water and is monitored as a secondary contaminant. Secondary contaminants are aesthetic (taste and odor) rather than health risks; however, in high concentrations sulfate can cause Diarrhea in some people.

THMs (Trihalomethanes): Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.

Total Dissolved Solids: (TDS) in drinking water is not a health hazard. The recommended upper limit has been established based on the aesthetic properties of water. Water high in TDS may taste salty or brackish. High TDS may also indicate that other ions naturally present in water may be above established regulatory levels.

VIOLATIONS:

Crescent Park received a reporting violation in 2014 for late submittal of HAA5 results in the 1st quarter of the year. This was a laboratory error, the results were issued to the state out of the specified time frame.

SOURCE WATER ASSESSMENT:

The New Jersey Department of Environmental Protection (NJDEP) has completed and issued the Source Water Protection Report and Summary for this public water system, which is available at www.nj.gov/dep/watersupply/swap/creport.htm or by contacting the NJDEP, Bureau of Safe Drinking Water at 609-292-5550. The table below illustrates the susceptibility rating for each individual source for each of the contaminant categories at this water system. For susceptibility ratings of purchased water, refer to the specific water system's source water assessment report. NJDEP considered all surface water highly susceptible to pathogens. For the purpose of the Source Water Assessment Program, radionuclides are more of a concern for ground water

than surface water. If the system is rated highly susceptible for a contaminant category, it does not mean that a customer is or will be consuming contaminated drinking water. The rating reflects the potential for contamination of source water, not the existence of contamination. Public water systems are required to monitor for regulated contaminants and to install treatment if any contaminants are detected at frequencies and concentrations above allowable levels. As a result of the assessments, NJDEP may customize (change existing) monitoring schedules based on the susceptibility ratings. If you have questions regarding the source water assessment report or summary, please contact the Bureau of Safe Drinking Water at 609-252-5550.

<u>Source Name</u>	<u>Pathogens</u>	<u>Nutrients</u>	<u>Pesticides</u>	<u>VOCs</u>	<u>Inorganics</u>	<u>Radionuclides</u>	<u>Radon</u>	<u>DBPs</u>
	<i>Ratings</i> L / M / H							
2 Wells	1 / 1	2	2	2	2	1 / 1	1 / 1	2

Susceptibility ratings for a public water system are based on the potential for a contaminant to be:

- At or above 50% of the Drinking Water Standard (MCL) = **(H) High**
- Between 10 and 50% of the Drinking Water Standard (MCL) = **(M) Medium**
- Less than 10% of the Drinking Water Standard (MCL) = **(L) Low**

Pathogens: Disease-causing organisms such as bacteria and viruses. Common sources are animal and human fecal wastes.

Nutrients: Compounds, minerals and elements that aid growth, and are both naturally occurring and man-made. Examples include nitrogen and phosphorus.

Volatile Organic Compounds (VOCs): Man-made chemicals used as solvents, degreasers, and gasoline components. Examples include benzene, methyl tertiary butyl ether (MTBE), and vinyl chloride.

Pesticides: Man-made chemicals used to control pests, weeds and fungus. Common sources include land application and manufacturing centers of pesticides. Examples include herbicides such as atrazine, and insecticides such as chlordane.

Inorganics: Mineral-based compounds that are both naturally occurring and man-made. Examples include arsenic, asbestos, copper, lead, and nitrate.

Radionuclides: Radioactive substances that are both naturally occurring and man-made. Examples include radium and uranium.

Radon: Colorless, odorless, cancer-causing gas that occurs naturally in the environment. For more information go to <http://www.nj.gov/dep/rpp/radon/index.htm> or call 800-648-0394.

(DBPs) Disinfectant Byproduct Precursors: A common source is naturally occurring organic matter in surface water. Disinfection byproducts are formed when other disinfectants (usually chlorine) used to kill pathogens react with dissolved organic material (for example leaves) present in surface water.

This Water Quality Report was prepared for Crescent Park by:

