



West Milford Municipal Utilities Authority

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

West Milford MUA Failed to Comply With a Testing Procedure

Our water system Bald Eagle Village recently failed to comply with a required testing procedure. Even though this was not an emergency, as our customers, you have a right to know what happened and what we did to correct the situation.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During 6/1/2014 to 9/30/2016, we did not complete all monitoring or testing for Lead & Copper by the 9/30/2016 deadline, and therefore cannot be sure of the quality of your drinking water during that time.

Any sample we collect must be sent to and analyzed by a certified laboratory within a specified amount of time. We collected the samples on November 15th through November 17th, 2016 and did not get the samples to the laboratory within the allowed holding time.

What should I do?

There is nothing you need to do at this time. You may continue to drink the water. If a situation arises where the water is no longer safe to drink, you will be notified within 24 hours.

What is being done?

On November 15, 16, & 17 2016 we collected new samples of our finished water in order to have it analyzed for Lead & Copper. We sent the sample to the certified lab via courier to ensure that the sample arrived within the allowed holding time. The sample was analyzed and Lead & Copper was not found at detectable levels.

For more information, please contact Kelly Love at 973-506-7330 or 179 Cahill Cross Road Suite 221 West Milford, NJ 07480.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by West Milford MUA. State Water System ID#: 1615018.
Date distributed: 11/28/16.